

Confirmation

LEED

On 27 March 2017, Eurofins Product Testing A/S received a sample of a chemical anchor with the product name:

Polymix SFPSF

supplied by

HAMAR SP. J. B. i H. Grzesiak

The sample was supplied as being representative of the manufactured product, and it has been tested as Multipurpose Construction Adhesives in accordance with the relevant ISO 16000, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2017-00105902_H_EN_07 and 392-2017-00106002_XD_EN_07).

The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m³ in both office and class room.

VOC content specifications in LEED EQ credit "Low-emitting products":

- The requirements of SCAQMD rule 1168 (2005)

6 November 2018


Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry


Paul Santner
Consultant

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.